

Product sheet



LEGRAND

T1+T2 12.5KA 2 poles surge arrester

REF. 412253 | EAN. 3414970518248

> Visit e-catalogue

Product charateristics

- T1+T2
- 12,5KA
- 2P

Recommendation / Restriction

• "To provide correct protection, a lightning arrester is recommended: - at the origin of each installation (mandatory depending on the type and location of the installation to be protected, - at the origin of divisional switchboards: secondary protection or fine protection of sensitive equipment, - on all outputs of external electrical circuits (supply to secondary buildings, external lighting or external electrical panels, etc.). A communication network arrester should always be installed to protect communication equipment in the presence of a lightning arrester on the low-voltage network."

Documentation

TECHNICAL DOCUMENTATION

- EXB20026_TG_Surge_Protective_Devices_EN.pdf | PDF (8.37Mo)
- F02060EN_05.pdf | PDF (0.62Mo)
- F02060FR_06.pdf | PDF (0.61Mo)
- → LE07561AA_6.pdf | PDF (0.53Mo)

CAD & Design specs / BIM

412233.dwg | DWG (0.37Mo)

CATALOGUE PAGE & OTHERS

- ex223001_0088-0089.pdf | PDF (0.16Mo)
- ex223001_0087.pdf | PDF (0.12Mo)
- ex223001_0084.pdf | PDF (0.08Mo)

Agreements & Certificates

■ LGRP-2015-068-V1-EN.pdf | PDF (0.62Mo)